

Addendum No. 1

Find yourself in good company

Project Name:	River Birch Tennis Center Roof	Project No.:	PC-0022
	Replacement		
Meeting Location:	River Birch Tennis Center	Meeting Date:	Thursday, June 15, 2017
	625 W. Arlington Blvd.		@ 10:00 AM
	Greenville, NC		
Prepared By:	Mike Watson	Date:	June 15, 2017

ATTENDEES:					
Name	Company	Phone No.	E-mail Address		
Mike Watson	City of Greenville	252-329-4539	mwatson@greenvillenc.gov		
Denisha Harris	City of Greenville	252-329-4862	dharris@greenvillenc.gov		
Brady Knowles	Owens Roofing Inc.	919-821-0082	brady@owensroofinginc.com		
Dewitt Newkirk	Unshakable Builders LLC	252-814-9105	dnewkirk@unshakablebuilders.com		
Eddie Chance	Chance & Smith Builders	252-531-4633	chanceandsmith@yahoo.com		
Char Harper	Curtis Construction Co.	252-398-5046	chad@curtiscc.com		

Clarifications & Requirements

- 1. Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addenda shall become part of the specifications and the bid package for the project.
- 2. Use the attached revised bid submittal sheet when turning in the bids.
- 3. On page 5, line number 2 under Material/Installation, delete all references to using copper products. Use standard flashing and white drip edge instead of copper.
- 4. For the purpose of this bid, all contractors are to include replacing a minimum of 5 sheets of sheathing. Any amount over the minimum will be a change order. Contractor is to notify the City prior to replacing any sheathing over the minimum.

Bids are due Tuesday, June 27, 2017 at the Jaycee Park Administration Building, 2000 Cedar Lane, Greenville, NC. Bids will be accepted up to 10:00 A.M. There will not be a public bid opening. Bids will opened by staff and a bid tabulation sheet will be available upon request once the contract is awarded to the successful bidder. *Note: Mailed proposals will be accepted up to the 10:00 A.M. deadline. All proposals received in the mail will be stamped with the date and time or receipt.*

Attachments:

1. Revised Bid Submittal Sheet

COG 1054235 Page 1

Bid Form

Roof Replacement – River Birch Tennis Center:

Revised 6/16/2017

Contractor Name and Address:					
	-				
Phone Number:					
Addenda Received:					
Date:					
Bid Amount:	\$				
Submitted by:					
Signature:	_				

BIDS ARE DUE BY 10:00 AM, TUESDAY, JUNE 27, 2017

COG 1054235 Page 2