

PANELBOARD RP36		VOLTAGE: <input type="checkbox"/> 208/120V, 3 PHASE, 4 WIRE <input type="checkbox"/> 240V, 3 PHASE, 4 WIRE		WIRE: <input type="checkbox"/> 480/277V, 3 PHASE, 4 WIRE <input type="checkbox"/> V, 3 PHASE, WIRE	
MOUNTING: <input type="checkbox"/> FLUSH <input type="checkbox"/> SURFACE		MAIN: <input type="checkbox"/> LUIGS ONLY <input type="checkbox"/> MAIN BREAKER		TRIP: <input type="checkbox"/> 225 A <input type="checkbox"/> 150 A	
COVER: <input type="checkbox"/> DOOR WITH LOCK <input type="checkbox"/> DOOR WITHOUT LOCK		<input type="checkbox"/> WITH HINGABLE COVER <input type="checkbox"/> WITHOUT HINGABLE COVER		ALL BRANCH BREAKERS 20A 1 POLE UNLESS NOTED OTHERWISE	
DESCRIPTION	LOAD	CKT NO.	DESCRIPTION	LOAD	PHASE LOAD (AMPS)
VAV UNIT 3-1, 2KW HEAT (4 #10, 1 #10 GND, 3/4")	2.4	1	VAV UNIT 3-8, 6KW HEAT (4 #10, 1 #10 GND, 3/4")	7.2	9.6
VAV UNIT 3-2, 5KW HEAT (4 #10, 1 #10 GND, 3/4")	6.0	7	SPACE	0.0	6.0
VAV UNIT 3-4, 12KW HEAT, (1) 1/2HP FANS (4 #10, 1 #10 GND, 3/4")	16.0	13	SPACE	0.0	16.0
VAV UNIT 3-5, 12KW HEAT, (1) 1/2HP FANS (4 #10, 1 #10 GND, 3/4")	16.0	23	SPACE	0.0	16.0
VAV UNIT 3-6, 7KW HEAT (4 #10, 1 #10 GND, 3/4")	8.4	31	SPACE	0.0	8.4
VAV UNIT 3-7, 5KW HEAT (4 #10, 1 #10 GND, 3/4")	6.0	39	SPACE	0.0	6.0
PANELBOARD LOCATION: ELECTRICAL ROOM 318 2ND FLOOR					
KEY: MULTIPOLE BREAKER, GFI BREAKER, LOCKOFF ATTACH, SWITCH DUTY, PADLOCK ATTACH, HACR, HID RATED, ARC FAULT					

PANELBOARD LP28		VOLTAGE: <input type="checkbox"/> 208/120V, 3 PHASE, 4 WIRE <input type="checkbox"/> 240V, 3 PHASE, 4 WIRE		WIRE: <input type="checkbox"/> 480/277V, 3 PHASE, 4 WIRE <input type="checkbox"/> V, 3 PHASE, WIRE	
MOUNTING: <input type="checkbox"/> FLUSH <input type="checkbox"/> SURFACE		MAIN: <input type="checkbox"/> LUIGS ONLY <input type="checkbox"/> MAIN BREAKER		TRIP: <input type="checkbox"/> 125 A <input type="checkbox"/> 150 A	
COVER: <input type="checkbox"/> DOOR WITH LOCK <input type="checkbox"/> DOOR WITHOUT LOCK		<input type="checkbox"/> WITH HINGABLE COVER <input type="checkbox"/> WITHOUT HINGABLE COVER		ALL BRANCH BREAKERS 20A 1 POLE UNLESS NOTED OTHERWISE	
DESCRIPTION	LOAD	CKT NO.	DESCRIPTION	LOAD	PHASE LOAD (AMPS)
LTS 101, 102, 128	4.2	1	LTS 127, 216, 319	1.8	6.0
LTS 105,107-109,112,115,118,121,123	9.0	3	LTS 201, 202, 224	4.7	13.7
LTS 103, 104, 113, 120, 122	5.7	5	LTS 205, 206, 209, 211-215, 217	10.2	15.9
LTS 106,110,111,114,116,117,124-126, BATH	7.6	7	LTS 218-222	7.2	14.8
SPACE	0.0	9	LTS 210	3.0	3.0
SPACE	0.0	11	LTS 203, 203B, 204, 207, 208, 223	6.6	6.6
OLC2B - FRONT WEST	7.5	13	SPACE	0.0	7.5
OLC2B - FRONT EAST	1.7	15	SPACE	0.0	1.7
OLC2B - BACK ENTRANCES	2.7	17	SPACE	0.0	2.7
SPACE - SPARE	0.0	19	SPACE	0.0	0.0
SPACE	0.0	21	SPACE	0.0	0.0
SPACE	0.0	23	SPACE	0.0	0.0
SPACE	0.0	25	SPACE	0.0	0.0
SPACE	0.0	27	SPACE	0.0	0.0
SPACE	0.0	29	SPACE	0.0	0.0
SPACE	0.0	31	SPACE	0.0	0.0
SPACE	0.0	33	SPACE	0.0	0.0
SPACE	0.0	35	SPACE	0.0	0.0
SPACE	0.0	37	SPACE	0.0	0.0
SPACE	0.0	39	SPACE	0.0	0.0
SPACE	0.0	41	SPACE	0.0	0.0
PANELBOARD LOCATION: ELECTRICAL ROOM 217 2ND FLOOR					
KEY: MULTIPOLE BREAKER, GFI BREAKER, LOCKOFF ATTACH, SWITCH DUTY, PADLOCK ATTACH, HACR, HID RATED, ARC FAULT					

PANELBOARD LP38		VOLTAGE: <input type="checkbox"/> 208/120V, 3 PHASE, 4 WIRE <input type="checkbox"/> 240V, 3 PHASE, 4 WIRE		WIRE: <input type="checkbox"/> 480/277V, 3 PHASE, 4 WIRE <input type="checkbox"/> V, 3 PHASE, WIRE	
MOUNTING: <input type="checkbox"/> FLUSH <input type="checkbox"/> SURFACE		MAIN: <input type="checkbox"/> LUIGS ONLY <input type="checkbox"/> MAIN BREAKER		TRIP: <input type="checkbox"/> 125 A <input type="checkbox"/> 150 A	
COVER: <input type="checkbox"/> DOOR WITH LOCK <input type="checkbox"/> DOOR WITHOUT LOCK		<input type="checkbox"/> WITH HINGABLE COVER <input type="checkbox"/> WITHOUT HINGABLE COVER		ALL BRANCH BREAKERS 20A 1 POLE UNLESS NOTED OTHERWISE	
DESCRIPTION	LOAD	CKT NO.	DESCRIPTION	LOAD	PHASE LOAD (AMPS)
LTS 303, 304, 305, 307, 308	4.4	1	SPACE	0.0	4.4
LTS 309	6.3	3	SPACE	0.0	6.3
LTS 309	6.6	5	SPACE	0.0	6.6
LTS 309	4.4	7	SPACE	0.0	4.4
LTS 309	4.0	9	SPACE	0.0	4.0
LTS 311-318	5.2	11	SPACE	0.0	5.2
LTS 301, 302, 310, 320, 321	7.4	13	SPACE	0.0	7.4
LTS 301	4.2	15	SPACE	0.0	4.2
SPACE	0.0	17	SPACE	0.0	0.0
SPACE	0.0	19	SPACE	0.0	0.0
SPACE	0.0	21	SPACE	0.0	0.0
SPACE	0.0	23	SPACE	0.0	0.0
SPACE	0.0	25	SPACE	0.0	0.0
SPACE	0.0	27	SPACE	0.0	0.0
SPACE	0.0	29	SPACE	0.0	0.0
SPACE	0.0	31	SPACE	0.0	0.0
SPACE	0.0	33	SPACE	0.0	0.0
SPACE	0.0	35	SPACE	0.0	0.0
SPACE	0.0	37	SPACE	0.0	0.0
SPACE	0.0	39	SPACE	0.0	0.0
SPACE	0.0	41	SPACE	0.0	0.0
PANELBOARD LOCATION: ELECTRICAL ROOM 318 3RD FLOOR					
KEY: MULTIPOLE BREAKER, GFI BREAKER, LOCKOFF ATTACH, SWITCH DUTY, PADLOCK ATTACH, HACR, HID RATED, ARC FAULT					

PANELBOARD RP1B1		VOLTAGE: <input type="checkbox"/> 208/120V, 3 PHASE, 4 WIRE <input type="checkbox"/> 240V, 3 PHASE, 4 WIRE		WIRE: <input type="checkbox"/> 480/277V, 3 PHASE, 4 WIRE <input type="checkbox"/> V, 3 PHASE, WIRE	
MOUNTING: <input type="checkbox"/> FLUSH <input type="checkbox"/> SURFACE		MAIN: <input type="checkbox"/> LUIGS ONLY <input type="checkbox"/> MAIN BREAKER		TRIP: <input type="checkbox"/> 225 A <input type="checkbox"/> 150 A	
COVER: <input type="checkbox"/> DOOR WITH LOCK <input type="checkbox"/> DOOR WITHOUT LOCK		<input type="checkbox"/> WITH HINGABLE COVER <input type="checkbox"/> WITHOUT HINGABLE COVER		ALL BRANCH BREAKERS 20A 1 POLE UNLESS NOTED OTHERWISE	
DESCRIPTION	LOAD	CKT NO.	DESCRIPTION	LOAD	PHASE LOAD (AMPS)
RECP 119	6.0	1	RECP 112	4.5	10.5
RECP 118	4.5	3	RECP 109	4.5	9.0
RECP 115	4.5	5	RECP 108	4.5	9.0
RECP 113, 127	7.5	7	RECP 107	6.0	13.5
RECP 121	4.5	9	RECP 106	6.0	10.5
RECP 123	6.0	11	RECP 103	3.0	9.0
RECP 102, 128	10.5	13	RECP 105	7.5	18.0
RECP UNSEX BATHROOM	1.5	15	RECP 104	4.5	6.0
RECP 122	3.0	17	RECP 104	4.5	7.5
RECP 124	6.0	19	RECP 101	6.0	12.0
RECP 116	6.0	21	DOOR OPENER - NORTH	4.0	10.0
RECP 116	6.0	23	DOOR OPENER - SOUTH	4.0	10.0
RECP 116	3.0	25	DOOR LOCK (2) 101, 117	2.0	5.0
RECP 116 DATA RACK	3.0	27	DOOR LOCK (2) 120, 103	2.0	5.0
RECP 116 COPIER	1.5	29	FIRE SHUTTER 104	8.2	9.7
RECP 114	4.5	31	VAV UNITS 1-1 TO 1-6	0.3	4.8
RECP 111	4.5	33	VAV UNITS 1-7 TO 1-12	0.3	4.8
RECP 110, 117	6.0	35	DOOR LOCK (2) 120, 127	2.0	8.0
RECP 125	7.5	37	ELEVATOR SUMP PUMP SP-1	3.1	10.8
RECP 126	7.5	39	RECP & LIGHT ELEVATOR PIT	1.5	9.0
RECP 103	6.0	41	FIRE DAMPERS (4)	2.7	8.7
PANELBOARD LOCATION: COORIDOR 113 1ST FLOOR					
KEY: MULTIPOLE BREAKER, GFI BREAKER, LOCKOFF ATTACH, SWITCH DUTY, PADLOCK ATTACH, HACR, HID RATED, ARC FAULT					

PANELBOARD RP1B2		VOLTAGE: <input type="checkbox"/> 208/120V, 3 PHASE, 4 WIRE <input type="checkbox"/> 240V, 3 PHASE, 4 WIRE		WIRE: <input type="checkbox"/> 480/277V, 3 PHASE, 4 WIRE <input type="checkbox"/> V, 3 PHASE, WIRE	
MOUNTING: <input type="checkbox"/> FLUSH <input type="checkbox"/> SURFACE		MAIN: <input type="checkbox"/> LUIGS ONLY <input type="checkbox"/> MAIN BREAKER		TRIP: <input type="checkbox"/> 225 A <input type="checkbox"/> 150 A	
COVER: <input type="checkbox"/> DOOR WITH LOCK <input type="checkbox"/> DOOR WITHOUT LOCK		<input type="checkbox"/> WITH HINGABLE COVER <input type="checkbox"/> WITHOUT HINGABLE COVER		ALL BRANCH BREAKERS 20A 1 POLE UNLESS NOTED OTHERWISE	
DESCRIPTION	LOAD	CKT NO.	DESCRIPTION	LOAD	PHASE LOAD (AMPS)
BLDG SERVICES	3.0	1	SPACE	0.0	3.0
SPACE	0.0	3	SPACE	0.0	0.0
SPACE	0.0	5	SPACE	0.0	0.0
SPACE	0.0	7	SPACE	0.0	0.0
SPACE	0.0	9	SPACE	0.0	0.0
SPACE	0.0	11	SPACE	0.0	0.0
SPACE	0.0	13	SPACE	0.0	0.0
SPACE	0.0	15	SPACE	0.0	0.0
SPACE	0.0	17	SPACE	0.0	0.0
SPACE	0.0	19	SPACE	0.0	0.0
SPACE	0.0	21	SPACE	0.0	0.0
SPACE	0.0	23	SPACE	0.0	0.0
SPACE	0.0	25	SPACE	0.0	0.0
SPACE	0.0	27	SPACE	0.0	0.0
SPACE	0.0	29	SPACE	0.0	0.0
SPACE	0.0	31	SPACE	0.0	0.0
SPACE	0.0	33	SPACE	0.0	0.0
SPACE	0.0	35	SPACE	0.0	0.0
SPACE	0.0	37	SPACE	0.0	0.0
SPACE	0.0	39	SPACE	0.0	0.0
SPACE	0.0	41	SPACE	0.0	0.0
PANELBOARD LOCATION: COORIDOR 113 1ST FLOOR					
KEY: MULTIPOLE BREAKER, GFI BREAKER, LOCKOFF ATTACH, SWITCH DUTY, PADLOCK ATTACH, HACR, HID RATED, ARC FAULT					

PANELBOARD RP2B1		VOLTAGE: <input type="checkbox"/> 208/120V, 3 PHASE, 4 WIRE <input type="checkbox"/> 240V, 3 PHASE, 4 WIRE		WIRE: <input type="checkbox"/> 480/277V, 3 PHASE, 4 WIRE <input type="checkbox"/> V, 3 PHASE, WIRE	
MOUNTING: <input type="checkbox"/> FLUSH <input type="checkbox"/> SURFACE		MAIN: <input type="checkbox"/> LUIGS ONLY <input type="checkbox"/> MAIN BREAKER		TRIP: <input type="checkbox"/> 225 A <input type="checkbox"/> 150 A	
COVER: <input type="checkbox"/> DOOR WITH LOCK <input type="checkbox"/> DOOR WITHOUT LOCK		<input type="checkbox"/> WITH HINGABLE COVER <input type="checkbox"/> WITHOUT HINGABLE COVER		ALL BRANCH BREAKERS 20A 1 POLE UNLESS NOTED OTHERWISE	
DESCRIPTION	LOAD	CKT NO.	DESCRIPTION	LOAD	PHASE LOAD (AMPS)
RECP - 202	6.0	1	RECP - 215	4.5	10.5
RECP - 203	6.0	3	RECP - 214 COPIER	1.5	7.5
RECP - 204	4.5	5	RECP - 214	7.5	12.0
RECP - 205	6.0	7	RECP - 210	3.0	9.0
RECP - 203B	9.0	9	RECP - 220	6.0	15.0
RECP - 207	4.5	11	RECP - 218	1.5	6.0
RECP - 205	6.0	13	RECP - 216	3.0	9.0
RECP - 206	4.5	15	RECP - 217	3.0	7.5
RECP - 209	3.0	17	RECP - 217	3.0	6.0
RECP - 211	4.5	19	RECP - 224	7.5	12.0
RECP - 212	4.5	21	VAV UNITS 2-1 TO 2-7	0.3	4.8
RECP - 213	7.5	23	HOT WATER HEATER WH-1, 218	8.3	15.8
RECP - 206	6.0	25	SPACE	0.0	0.0
RECP - 206	6.0	27	SPACE	0.0	0.0
RECP - 208 COPIER	1.5	29	SPACE	0.0	0.0
RECP - 221	6.0	31	SPACE	0.0	0.0
RECP - 221	6.0	33	SPACE	0.0	0.0
RECP - 221	6.0	35	SPACE	0.0	0.0
RECP - 223	9.0	37	SPACE	0.0	0.0
RECP - 222	9.0	39	SPACE	0.0	0.0
RECP - 219	6.0	41	SPACE	0.0	0.0
PANELBOARD LOCATION: ELECTRICAL ROOM 217 2ND FLOOR					
KEY: MULTIPOLE BREAKER, GFI BREAKER, LOCKOFF ATTACH, SWITCH DUTY, PADLOCK ATTACH, HACR, HID RATED, ARC FAULT					

PANELBOARD RP2B2		VOLTAGE: <input type="checkbox"/> 208/120V, 3 PHASE, 4 WIRE <input type="checkbox"/> 240V, 3 PHASE, 4 WIRE		WIRE: <input type="checkbox"/> 480/277V, 3 PHASE, 4 WIRE <input type="checkbox"/> V, 3 PHASE, WIRE	
MOUNTING: <input type="checkbox"/> FLUSH <input type="checkbox"/> SURFACE		MAIN: <input type="checkbox"/> LUIGS ONLY <input type="checkbox"/> MAIN BREAKER		TRIP: <input type="checkbox"/> 225 A <input type="checkbox"/> 150 A	
COVER: <input type="checkbox"/> DOOR WITH LOCK <input type="checkbox"/> DOOR WITHOUT LOCK		<input type="checkbox"/> WITH HINGABLE COVER <input type="checkbox"/> WITHOUT HINGABLE COVER		ALL BRANCH BREAKERS 20A 1 POLE UNLESS NOTED OTHERWISE	
DESCRIPTION	LOAD	CKT NO.	DESCRIPTION	LOAD	PHASE LOAD (AMPS)
RECP BLDG SERVICES	3.0	1	SPACE	0.0	3.0
SPACE	0.0	3	SPACE	0.0	0.0
SPACE	0.0	5	SPACE	0.0	0.0
SPACE	0.0	7	SPACE	0.0	0.0
SPACE	0.0	9	SPACE	0.0	0.0
SPACE	0.0	11	SPACE	0.0	0.0
SPACE	0.0	13	SPACE	0.0	0.0
SPACE	0.0	15	SPACE	0.0	0.0
SPACE	0.0	17	SPACE	0.0	0.0
SPACE	0.0	19	SPACE	0.0	0.0
SPACE	0.0	21	SPACE	0.0	0.0
SPACE	0.0	23	SPACE	0.0	0.0
SPACE	0.0	25	SPACE	0.0	0.0
SPACE	0.0	27	SPACE	0.0	0.0
SPACE	0.0	29	SPACE	0.0	0.0
SPACE	0.0	31	SPACE	0.0	0.0
SPACE	0.0	33	SPACE	0.0	0.0
SPACE	0.0	35	SPACE	0.0	0.0
SPACE	0.0	37	SPACE	0.0	0.0
SPACE	0.0	39	SPACE	0.0	0.0
SPACE	0.0	41	SPACE	0.0	0.0
PANELBOARD LOCATION: ELECTRICAL ROOM 271 2ND FLOOR					
KEY: MULTIPOLE BREAKER, GFI BREAKER, LOCKOFF ATTACH, SWITCH DUTY, PADLOCK ATTACH, HACR, HID RATED, ARC FAULT					

PANELBOARD RP3B1		VOLTAGE: <input type="checkbox"/> 208/120V, 3 PHASE, 4 WIRE <input type="checkbox"/> 240V, 3 PHASE, 4 WIRE		WIRE: <input type="checkbox"/> 480/277V, 3 PHASE, 4 WIRE <input type="checkbox"/> V, 3 PHASE, WIRE	
MOUNTING: <input type="checkbox"/> FLUSH <input type="checkbox"/> SURFACE		MAIN: <input type="checkbox"/> LUIGS ONLY <input type="checkbox"/> MAIN BREAKER		TRIP: <input type="checkbox"/> 150 A <input type="checkbox"/> 150 A	