

**Addendum No. 1**

<b>Project Name:</b>	Asphalt Parking Lot – Eppes Recreation Center	<b>Project No.:</b>	PC-0010
<b>Meeting Location:</b>	Eppes Recreation Center 400 Nash Street Greenville, NC	<b>Meeting Date:</b>	Tuesday, August 16, 2016 @ 9:00 AM
<b>Prepared By:</b>	Mike Watson	<b>Date:</b>	August 16, 2016

<b>ATTENDEES:</b>			
<b>Name</b>	<b>Company</b>	<b>Phone No.</b>	<b>E-mail Address</b>
Mike Watson	City of Greenville	252-329-4539	<a href="mailto:mwatson@greenvillenc.gov">mwatson@greenvillenc.gov</a>
Denisha Harris	City of Greenville	252-329-4862	<a href="mailto:dharris@greenvillenc.gov">dharris@greenvillenc.gov</a>
Jesse Garris	Garris Paving	252-749-1101	<a href="mailto:garrispaving@gmail.com">garrispaving@gmail.com</a>
James Pearsall	Absolute Pavement Services	252-823-7283	<a href="mailto:jpearsall@absolute-pavement.com">jpearsall@absolute-pavement.com</a>
Fennell Moses Jr	Moses Paving	252-756-3437	<a href="mailto:yokie1223@aol.com">yokie1223@aol.com</a>
Bruce Coward	Carolina Earth Movers	252-531-2063	<a href="mailto:bcoward@carolinaearthmovers.com">bcoward@carolinaearthmovers.com</a>
Paul Heatherington	S.T. Wooten	919-437-2319	<a href="mailto:paul.heatherington@stwc.com">paul.heatherington@stwc.com</a>

**Clarifications & Requirements**

1. Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addenda shall become part of the specifications and the bid package for the project.
2. Use the attached revised bid submittal sheet when turning in the bids. Provide a bid price for each line item.
3. In the base bid, remove from the scope of work the repairing and patching of the existing rear parking lot. Include in the base bid, the saw cutting of the driveway at the end of the curbs and the parking lot, remove the existing asphalt parking lot and grade and prepare the area to receive a minimum thickness of 2” of new asphalt.
4. Resurface the driveway with a minimum thickness of 1.5” of new covering and edge mill the curb and gutters.
5. Include removing the old cement dumpster pad. Fill in with soil and plant grass seed.
6. Delete all references to seal coating.

**Bids are due Thursday, August 25, 2016 at the Jaycee Park Administration Building, 2000 Cedar Lane, Greenville, NC. Bids will be accepted up to 2:00 P.M. There will not be a public bid opening. Bids will be opened by staff and a bid tabulation sheet will be available upon request once the contract is awarded to the successful bidder. *Note: Mailed proposals will be accepted up to the 2:00 P.M. deadline. All proposals received in the mail will be stamped with the date and time or receipt.***

**Attachments:**

1. Revised Bid Submittal Sheet

**Eppes Resurface Asphalt Parking Lot:**

**Contractor Name and Address:**

---

---

---

---

**Phone Number:** \_\_\_\_\_

**Date:** \_\_\_\_\_

**Base Bid Amount:** \$ \_\_\_\_\_

**Addenda Received:** \_\_\_\_\_

**Bid submitted by:** \_\_\_\_\_

**Signature:** \_\_\_\_\_

Notes:

- 1. Bid will be considered valid for a period of 60 days after submittal**
- 2. City has the right to accept or reject any or all parts of the bids.**

**Alternate #1:** Install new striping on the front parking lot to match the existing layout.

\$ \_\_\_\_\_

**Alternate #2:** Install new dumpster pad.

\$ \_\_\_\_\_