


PUBLIC WORKS

**To:** All Interested Bidders and plan holders

**From:** James Lynn Raynor, PE 

**RE:** 2016 Bond Street Repairs, Phase 2, PWD-2016-004  
Addendum #1

**Date:** September 6, 2016

**The following items clarify, add to, delete from and/or otherwise change and supersede information previously issued to you in the Bid Documents for the above-referenced project. As such, said items shall be considered part of the contract and receipt of this addendum shall be acknowledged appropriately in the bid package. Please review the following items carefully and adjust your proposal accordingly.**

Pre-bid Minutes/Clarifications/Follow-up:

1. No bidders were present for the pre-bid meeting, so the pre-bid meeting was cancelled.
2. Work on the items of wheel chair ramps and new signal equipment may be performed during normal business hours of 8:00 AM to 5:00 PM.
3. New signal equipment must be installed and operational prior to milling operations at each intersection that would remove the existing loop infrastructure.
4. Milling of existing asphalt pavement is limited to a depth of 1.75" to ensure safe drop-offs for vehicles are not exceeded.
5. For Item #11, Portable Lighting, it is assumed four (4) lights will be needed during a given night operation; however, adjustments may be made depending on the contractor's operations.
6. Temporary Paint Markings will be incidental to the work of the contract.

Changes/Additions to Bid List and Specifications:

1. None

Requests for additional information:

1. None

Any questions regarding this Addendum should be directed to Mr. Lynn Raynor, PE, at telephone 252-329-4620 or email at [lraynor@greenvillenc.gov](mailto:lraynor@greenvillenc.gov).

ec: Kevin Mulligan, PE, Public Works Director  
Scott Godefroy, PE, City Engineer  
Ronnie Donley, Streets Superintendent