

## ADDENDUM

P.O Box 7207 | Greenville, NC 27835-7207 | phone 252-329- 4554 | swarner@greenvillenc.gov

ADDENDUM #: DATE:	5 January 31, 2017	GRPD PROJECT#	COG DOC # 1043610	
PROJECT:	Fence Repair and Replace	ence Repair and Replacement 2017		

This Addendum is hereby made a part of the Contract Documents to the same extent as if originally included herein. This Addendum must be acknowledged and shall be placed with the Contract Documents.

The Request for Bid Proposals and bid documents for this project are hereby modified, corrected or supplemented as follows: in **BOLD** 

Bid Amounts:	
Approx. 110' of 4' galvanized chain link	\$
Approx. <b>250</b> ' of 4' galvanized chain link	\$
Approx. 228' of 4' galvanized chain link	\$
Approx. 231' of 4' black vinyl chain link	\$
TOTAL \$	

And

## Material/Installation

- 1. Contractor is responsible for verifying all measurements.
- 2. Furnish and install approximately **588**' of 4' high fence fabric. Fabric shall be 9 gauge galvanized with 2" mesh.
- 3. Furnish and install approximately 231' of 4' black vinyl fence fabric. Fabric shall be 11 gauge core with 2" mesh.

## END OF ADDENDUM # 5