

**Addendum No. 1**

<b>Project Name:</b> Fire Rescue 5 Roof Replacement	
<b>Meeting Location:</b> 255 Rollins Street, Greenville, NC	<b>Pre-Bid Meeting Date:</b> October 5, 2017
<b>Prepared By:</b> Ross Peterson	<b>Date:</b> October 12, 2017

<b>ATTENDEES:</b>			
<b>Name</b>	<b>Company</b>	<b>Phone No.</b>	<b>E-mail Address</b>
Ross Peterson	City of Greenville	252-329-4921	<a href="mailto:rpeterson@greenvillenc.gov">rpeterson@greenvillenc.gov</a>
Adam Draughan	Brewers Roofing	252-399-0026	brewersroofing@yahoo.com
Teddy Womack	Martin Enterprise	336-253-4810	martinsenterprisellc@yahoo.com
Bob Barry	BM Roofing	252-9553253	bbarry@bmroofingcontractors.com
David Tedder	DLT Roofing	919-284-5800	dltroofing@yahoo.com
Steve Yoder	Yoder Home Improvements	252-933-9258	Syoder1974@gmail.com
Randy Eddington	WaynCo Roofing	704-814-9566	randyeddington@hotmail.com
Brady Knowles	Owens Roofing	919-821-0082	brady@owensroofinginc.com
Todd Casey	Best Distributers	919-735-1651	tcasey@bestdist.com
Chad Harper	Curtis Construction	252-378-5048	chad@curtiscc.com
Adam Corey	W.A. Corey Construction	252-217-8770	wacoreyinc@aol.com

**Clarifications & Requirements**

1. Acknowledgement of all addendum received must be noted on the bid submittal form. Any and all addendums shall become part of the specifications and the bid package for the project
2. Signature required for acknowledgment of addendum
3. Question: Do we replace lead boots with lead boots?  
Answer: Replace all boots with like boots
4. Question: Does the entire roof get ice and water shield?  
Answer: Yes
5. Question: Does the EPDM section of roof get replaced?  
Answer: No

**Bids are due Thursday October, 19, 2017 at the Public Works Building, 1500 Beatty Street, Greenville, NC. Bids will be accepted up to 2:00 P.M.**

*End of Addendum #1*