

Addendum No. 1

Project Name: Tennis Court Resurfacing Various Parks	Project No.: PC-0091
Prepared By: Mike Watson	Date: May 20, 2020

Items:

1. Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addenda shall become part of the specifications and the bid package for the project.
2. The last day to submit questions shall be Tuesday, May 26, 2020 by 10:00 AM.
3. The following material is approved for use:
 - a. Surface One Sports Coating by Sherwin Williams
 - b. Acrytech
 - c. Plexipave
 - d. Novacrylic Combo & Novasurface
 - e. Armor crack repair system
4. Clarification page 5, line #9: Base bid shall include one coat of resurfacer and two coats of acrylic top coating.
5. Replace page 5, line #13: Contractor shall warrant all material and workmanship for a period of two (2) years on the installation of all coatings. Cracks (1/4" or greater) that are repaired using a crack repair system shall also have a two (2) year warranty period. It is understood that cracks (less than 1/4") that are not repaired using a crack repair system are not covered under the warranty.
6. Add page 6, line #15: Contractor shall provide references on request of similar projects completed and may be a determining factor in the award of the bid.
7. Add Alternate #2: Install second coat of resurfacer at Elm Street Park and Thomas Foreman Park courts only.

Bids are due Tuesday, June 2, 2020 via email or mailed to the Jaycee Park Administration Building, 2000 Cedar Lane, Greenville, NC. Bids will be accepted up to 3:00 PM. There will not be a public bid opening. Bids will be opened by staff and a bid tabulation sheet will be available upon request once the contract is awarded to the successful bidder.

Attachment: Revised Bid Form

Bid Form

Tennis Court Resurfacing – Various Parks

Contractor Name and Address:

Phone Number: _____ **Date:** _____

Base Bid Amount: \$ _____

Alternate #1 LF Amount: \$ _____

Alternate #2 Amount: \$ _____

Unit Price #1 Amount: \$ _____

Unit Price #2 Amount: \$ _____

Addenda: _____

Submitted by: _____

Signature: _____

BIDS ARE DUE BY 3:00 PM, TUESDAY, JUNE 2, 2020