

**RFP# 20-21-12
Public Works Security
Fence Upgrades**

Addendum #1

Project Name: Project No.: RFP# 20-21-12
Prepared By: Aaron Lewis Date: October 7, 2020

General Questions, Clarifications, & Requirements:

1. Items 1-4 on pages 6 & 7 reading “Provide and install two (2) Keyscan- compatible combination card reader/keypad and required accessories and **controller.**” will now read “Provide and install two (2) Keyscan-compatible combination card reader/keypad and required accessories and **one (1) Keyscan 8500CA 8-door controller.**”

2. Item 4 on page 7 reading “Provide and install three fabricated gates, using dimensions of existing gates, with self-closing hinges, panic bar exit, and **600 lb. mag lock,** with card/keypad entry.” will now read “Provide and install three fabricated gates, using dimensions of existing gates, with self-closing hinges, panic bar exit, and **electric strike,** with card/keypad entry.”

3. Items 1-2 on pages 6 & 7 reading “Provide and install two (2) Aiphone IX series intercom/camera combination **or equivalent device** and required accessories and controller. **Master station to be located in Building A reception office, with audio/video and gate opening capability.**” will now read “Provide and install two (2) Aiphone IX series intercom/camera combination and required accessories and controller. **Provide and program five (5) Aiphone IX-Soft PC Master Station Software installations with lifetime, transferable license per PC.**”

End of Addendum #1