

RFP# 20-21-18
Public Works Administration and Fleet Buildings Restroom Renovations

Addendum #1

Project Name: Project No.: RFP# 20-21-18	
Prepared By: Aaron Lewis	Date: December 3, 2020

All addenda must be acknowledged on the bid form. All addenda become part of the specification and bid package for the project.

General Requirements, Questions & Clarifications:

1. Replace page 9, item 7.d. & page 14, item 4: Replace existing light fixture with 2' x 4' 5000k, 50 W LED troffer fixture. Replace existing light switches with motion-sensing automatic switches.

2. Question: Will bid price reflect standard or non-standard colors for the partitions and countertops?

Answer: Base bid pricing will be for standard colors. The Owner will assume additional costs, if non-standard colors are chosen.

3. Question: How should pricing be itemized?

Answer: Pricing should be itemized by trade.

4. Question: Do you have a PDF of the plans available?

Answer: No

5. Question: Will debris disposal be available on-site?

Answer: No. Debris must be removed from the property and properly disposed of.

6. Question: Will the over-mirror light fixture in the Assembly Room Men's room be replaced.

Answer: Yes. The existing light fixture is to be replaced with a 5000k LED fixture of similar design.

7. Question: Will a licensed plumber/electrician be required to install plumbing/electrical fixtures.

8. Answer: Yes.

9. Clarification: All partition walls and doors are to be solid plastic.

End of Addendum #1