

REV	DATE	DESCRIPTION	BY	CHK
0	1/15/21	ISSUED FOR CONSTRUCTION		
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				

General Notes

1. MINIMUM THICKNESS OF INSULATING BOARD AT ROOF DRAINS SHALL BE 5".
2. ROOF DRAINS - UNDERSIDES TO BE SPRAY FIREPROOFED (1 HR PROTECTION MIN.). SEE PLUMBING DINGS FOR DETAILS.
3. OVERFLOW ROOF DRAIN TO BE 2" ABOVE PRIMARY ROOF DRAIN.
4. ALL ROOFS SHALL SLOPE TO DRAIN AT 1/4" PER FOOT, MINIMUM.
5. SEE ELECTRICAL DRAWINGS FOR LIGHTNING PROTECTION

Keyed Notes

- 1 NEW FULLY ADHERED SINGLE PLY MEMBRANE ROOFING SYSTEM OVER EXISTING EPDM ROOFING ASSEMBLY - SEE DETAILS
- 2 EXISTING TPO ROOF MEMBRANE TO REMAIN.
- 3 NEW TWO PIECE PRE-FINISHED METAL COPING ASSEMBLY, DOWNSPOUTS
- 4 NEW 9"x9" CONTINUOUS GUTTER AND 5"x5" DOWNSPOUTS
- 5 PROVIDE SPASH BLOCKS AT EVERY ROOF DISCHARGE DOWNSPOUT-TYPICAL



1 ROOF PLAN
 1/16" = 1'-0"
 NORTH