

**City of Greenville
Invitation to Bid
Generator/Transfer Switch Replacement
Public Works Administration & Municipal Building**

Addendum No. 1

Project Name: Generator/Transfer Switch Replacement Public Work Administration & Municipal Building
--

Prepared By: Ross Peterson

Date: April 4, 2022

General Questions, Clarifications & Requirements:

Q; Clarification on fuel filtering for current diesel full.

A; This is will be excluded from bid. The City of Greenville will manage this process.

Q; What generator voltage is needed?

A; 208v for both generator. This shall be confirmed by contractor with Cummins representative.

Q; What generator amps is needed?

A; 260amps for Municipal Building, 800amps for Public Works. This shall be confirmed by contractor with Cummins representative.

Q; What ATS enclosure?

A; Both the Municipal Building and Public Works Administration are indoor so both need to be NEMA1.

End of Addendum #1