

Addendum No. 5

Project Name: Parking Lot Expansion Thomas Foreman Park	Project No.: PC-0128
Prepared By: Mike Watson	Date: October 20, 2023

Clarifications & Requirements:

1. Acknowledgement of all addenda received must be noted on the bid submittal form. Any and all addenda shall become part of the specifications and the bid package for this project.
2. On sheet C3.1, delete detail 8/C3.1 for the steel fence.
3. In the base bid the fence shall be:
 - a. Furnish and install new 4’ high, 2” mesh chain link fence with 9 gauge wire with an 8 gauge vinyl finish. Color for the fence and all components shall be black.
 - b. Knuckled at the top and bottom.
 - c. Include a bottom tension wire at all fence fabric
 - d. All fence ties shall be steel and all posts and rails shall be SS20
 - e. Top and bottom rails shall be 1 5/8”, line posts shall be 2” and terminal posts shall be 2 ½”.
 - f. Provide no openings for a walk through.
4. In Alternate #1, in lieu of the chain link fence, the fence material shall be aluminum and match the existing design of the fence at pool located on the property. The height of the fence shall be 4’ and the color shall be black.
5. Please note, the new wood bollards that are to be installed shall match the old ones being removed.

Bids are due Tuesday, October 24, 2023 via email to mwatson@greenvillenc.gov or mailed to the Jaycee Park Administration Building, 2000 Cedar Lane, Greenville, NC. Bids will be accepted up to 2:00 PM. There will not be a public bid opening. Bids will be opened by staff and a bid tabulation sheet will be available upon request once the contract is awarded to the successful bidder.