

## Wildwood Park Beach Improvements Addendum No. 02



<b>Project Name:</b> Wildwood Park Beach Improvements	<b>Project No.:</b> RFP#24-25-11
<b>Prepared By:</b> Mark Nottingham	<b>Date:</b> 10-02-2024

### **Project Clarifications:**

- The sand to be used for the beach area shall be prewashed and 0.6-1 mm in size.
- Epoxy coated rebar is not required.
- The stone top in bid alternate A shall be natural stone, light beige sandstone, and sample must be approved by the owner prior to installation.
- MWBE forms are required for projects \$100K and above. This project is expected to bid below that amount.