

SUBJECT: ADDENDUM NO. 2

September 8, 2015

To the Plans and Specifications for
City of Greenville, NC
Police-Fire-Rescue Headquarters - Emergency Generator Replacement

To: PROSPECTIVE BIDDERS AND OTHER CONCERNED

This ADDENDUM forms a part of the Contract Documents and modifies the original Bidding Documents as noted below. Bidders shall acknowledge receipt of the ADDENDUM in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

A. Drawing Changes:

1. Sheet E0.1:
 - a. In the heading "Fire Resistance Cables Requirements", remove note number 1 wording "*MARMON WIRE & CABLE INC, TYPE MC (METAL CLAD) VITALINK MC BRAND. TO BE INSTALLED AS DESCRIBED IN UL SYSTEM NO. 120 (FHIT-120) ELECTRICAL CIRCUIT INTEGRITY SYSTEMS AND IN ACCORDANCE WITH THE MANUFACTURE'S INSTALLATION INSTRUCTIONS.*" and replace with wording "NOTE NOT USED." It has been determined that Marmon Wire & Cable Inc, Type MC (Metal Clad) Vitalink MC Brand will not satisfy the requirements of NEC Article 708 Critical Operations Power Systems (COPS).

B. Clarifications:

1. The method for "Protection Against Physical Damage" and "Fire Protection for Feeders" for the wiring that is indicated in the bid documents as "2 Hr Fire Rated Cable" shall meet the requirements of NEC Article 708 Critical Operations Power Systems (COPS).
2. Referencing NEC Article 708 (C)(2) Fire Protection of Feeders: Methods for Fire Protection For Feeders shall include, but are not limited to:
 - a. "MI" (Mineral Insulated) cable,
 - b. Protected by a listed fire-rated assembly that has a minimum fire rating of 2 hours
 - o A listed fire-rated assembly could include a conduit wrap or spray-on product.
 - c. Encased in a minimum of 2 inches of concrete.

C. Revised Bid Opening Data and Time:

1. The Bid Opening date has been rescheduled for Thursday September 17, 2015 at 2:00 PM.

FOR THE OWNER
CITY OF GREENVILLE, NC

END OF DOCUMENT